

ERC Testing Ltd.

Unit A8(3), Pennington Court, Moss Industrial Estate, Leigh Lancashire WN7 3PT

Tel: 01942 603927. Company Registration No. 9819101



REPORT NUMBER:	901153		
CLIENT:	BAKO OKNA		
PRODUCT:	VERTICAL SLIDING SASH WINDOW (SPIRAL BALANCE)		
SIM-SOFTWARE:	WINISO (VERSION 2.8.1)		
MATERIAL:	SOFTWOOD		
GLASS CONFIGURE:	4CLEAR/16/4PLANITHERM ONE, SWISSPACER ADVANCE SPACER		
SEALANT:	HOTMELT BUTYLE		
CENTRE PANE U-VALUE (U _G):	1.042	W/M2K	
SOLAR FACTOR (g):	0.52		
THERMAL TRANSMITTANCE (U-VALUE):	1.2	W/M2K	
ENERGY INDEX:	N/A		
ENERGY RATING:	N/A		

Approved testing body, registered with UKAS under accreditation number **23361**, and is a registered company at the Ministry of Housing, Communities and Local Government (MHCLG) under number **8544**.

Authorised by:-

Signature

A handwritten signature in black ink, appearing to read 'Fradley', is written over a light blue horizontal line.

Peter Fradley
ERC Testing Ltd
Date:

Version: V0
Date: 14th February 2025